

1. (A) DENOTES A PUMP STATION DIMENSION/SIZE OR ELEVATION – SEE SCHEDULE.
2. ALL PIPING TO BE FLANGED BY PLAIN END D.I.P., UNLESS NOTED OTHERWISE.
3. ALL FITTINGS INSIDE WET WELL AND VALVE VAULT TO BE FLANGED AND BITUMINOUS COATED, MINIMUM 1 MIL. THICK.
4. ALL HARDWARE (BOLTS, BRACKETS, GUIDE BARS, CHAINS, ETC.) INSIDE WET WELL AND VALVE VAULT TO BE STAINLESS STEEL. ANY BRACKET FURNISHED BY THE PUMP MANUFACTURER WHICH IS NOT STAINLESS STEEL SHALL BE EPOXY COATED, SUBJECT TO PRIOR APPROVAL BY THE COMMISSION.
5. ALL PIPE OPENINGS IN WET WELL AND VALVE VAULT TO BE CORED AND FITTED WITH NEOPRENE RUBBER BOOTS.
6. VALVE VAULT PIPING SHALL BE SUPPORTED WITH MASONRY OR STEEL SUPPORTS AT A MINIMUM OF 3 POINTS.
7. ALUMINUM ACCESS DOORS AND FRAMES TO BE HALLIDAY PRODUCTS, SERIES S1R, OR APPROVED EQUAL.
8. AN EXTENSION TYPE OR SINGLE SECTION ALUMINUM LADDER OF SUFFICIENT LENGTH TO ENTER THE WET WELL SHALL BE PROVIDED. LADDER TO BE CHAINED AND PADLOCKED TO THE INSIDE OF THE FENCE WHEN NOT IN USE.

DATE: 4/29/94	REVISIONS	STANDARD DETAIL	LEXINGTON COUNTY JOINT MUNICIPAL WATER AND SEWER COMMISSION
SCALE: NTS		GENERAL NOTES	FILE NO. SP006F1