



CAUTION  
DO NOT BLOCK DRAIN  
HOLES WITH CONCRETE

2 CU. FT. GRAVEL  
AROUND DRAIN PORTS

36" MIN. COVER

2' MINIMUM

M & H POST HYDRANT STYLE 33  
ONE 2 1/2" HOSE NOZZLE.

CONC. VALVE PROTECTOR RING  
WHEN NOT IN PAVED AREA

VALVE BOX

2" NRS GATE VALVE

4" WATERMAIN

4" MJ CAP TAPPED 2"  
(W/MEGALUGS)

2" x 8" DIP  
THREADED NIPPLE

2" x 24" DIP  
THREADED NIPPLE

2'x2'x2" CONC. BLOCK

DATE: 7/1/93  
REVISIONS

SCALE: NTS  
MAY 6, 1994  
FEB. 21, 2000  
JUNE, 2009

STANDARD DETAIL

POST TYPE HYDRANT BLOW-OFF  
FOR 4" WATER MAINS

LEXINGTON COUNTY  
JOINT MUNICIPAL  
WATER AND SEWER  
COMMISSION

FILE NO. WLO02