



① VALVES & BLOW-OFFS ARE NOT REQUIRED FOR CREEK CROSSINGS WITH BANK TO BANK DISTANCES LESS THAN 15' FEET.

DATE: 9/1/97	REVISIONS	STANDARD DETAIL	LEXINGTON COUNTY JOINT MUNICIPAL WATER AND SEWER COMMISSION
SCALE: NTS			STANDARD STREAM CROSSING (MIN. REQUIREMENTS, PIPES 12" AND UNDER)
		FILE NO.	WL016